

Midocean University



College of administration

Master of Project Management

Enhancing Transformer Sustainability in Saudi Arabia's Power

Transmission Projects: A Contextual Exploration of Advanced

Gasket Technologies and Leak Detection Methods to Mitigate Oil

Leaks

Student Name/ESSA HASSAN GHAZWANI

Supervision/

Dr. Alfaisal Hasan

Dr. Fayez Jrad

Academic Year:

2025



Table of contents

Chapter One	1
Abstract	7
Introduction	9
Study Problem	11
Importance of the Study	14
Objectives of the Study	15
Study Questions	17
Study Assumptions	19
Study terms	20
Study variables	22

Chapter Two	26
Previous Studies	27
Theoretical framework	30
The Concept of Sustainability in the Energy Sector:	34
Power Transformers and Their Vital Role in Energy Transmission Networks:	38
Oil Leakages in Transformers: Causes and Effects:	42
Advanced Heater Gasket Technologies for Transformers:	46

Methods of Leakage Detection in Transformers:	50
The Role of Predictive Maintenance in Reducing Oil Leakages:	54
Best Practices in Transformer Oil Management:	58
Future Trends in Sustainable Transformer Technology:	62
Regulatory Framework and Incentives to Promote Transformer Sustainability in the Kingdom of Saudi Arabia:	66
Conclusion	69

Chapter Three	71
Study methodology	72
Study community	73
Data collection tools	74
Limits of the study	75
Chapter Four	85
Statistical analysis	86
Results	88
Recommendations	93
References	69
Appendices	100

Abstract:

This research addresses the critical issue of transformer oil leaks in Saudi Arabia's power transmission infrastructure, focusing on gasket failures as a primary cause. By investigating gasket degradation mechanisms, evaluating leak detection methods, and exploring advanced gasket materials such as nanocomposites and smart gaskets, this study aims to enhance transformer sustainability. The proposed solutions align with Saudi Arabia's Vision 2030 goals, emphasizing environmental protection, operational efficiency, and economic viability. Experimental data from laboratory and field tests, including tensile strength, elongation, and accelerated

aging, are analyzed to evaluate the effectiveness of new gasket technologies. The findings aim to reduce oil leak incidents by 10–15%, lower maintenance costs, and extend transformer lifespans.

Introduction

Saudi Arabia is experiencing an increasing demand for electricity driven by rapid urbanization and industrial growth. Power transformers, which are vital for ensuring a reliable electricity supply, often suffer from oil leaks primarily due to gasket failures. As Lakhiani (2014) emphasizes, "Eco-friendly leak-proof transformers are essential for sustainable power systems," underscoring the importance of tackling this issue.

The repercussions of these leaks extend beyond environmental concerns; they also threaten the economic stability of the power sector. Leaked oil can contaminate ecosystems, endangering wildlife and heightening fire

risks. According to Islam Ali (2024), while Saudi Arabia's transition to green energy is essential, it is also complex.

Despite recent initiatives aimed at diversifying energy sources, the Gulf Cooperation Council (GCC) is under significant environmental scrutiny regarding the effects of hydrocarbon investments. This situation underscores the urgent need for effective strategies to prevent and mitigate transformer oil leaks, thereby supporting the Kingdom's sustainability objectives.

This research aims to investigate the causes of gasket degradation, assess advanced leak detection techniques, and explore innovative gasket technologies to improve transformer sustainability in Saudi Arabia.

1.2 Study Problem

Main Problem: Transformer Oil Leaks in Saudi Arabia's

Power Transmission Infrastructure

Transformer oil leaks pose a significant challenge within

Saudi Arabia's power transmission infrastructure, leading

to several critical issues:

1. Environmental Pollution: The leakage of transformer oil

results in the contamination of soil and groundwater,

which severely harms local ecosystems.

2. Economic Losses: The financial implications are

substantial, encompassing costs related to repairs,

environmental remediation, and the economic impact of

power outages.

3. Safety Hazards: Oil leaks increase the risk of fires and electrical hazards, posing serious safety threats to both personnel and the surrounding communities.

4. Operational Disruptions: These leaks can lead to unplanned outages, ultimately reducing the reliability of the power grid.

As Lakhiani (2014) emphasizes, there is a pressing need for eco-friendly gasket designs to mitigate oil leaks, underscoring the importance of developing durable and reliable sealing solutions.

The degradation mechanisms that contribute to these leaks are intensified by Saudi Arabia's harsh desert

climate. Factors such as aging, thermal stress, chemical exposure, and mechanical strain are particularly problematic.

Moreover, research by Osama E. Gouda, Saber M.

Saleh, and Salah Hamdy EL-Hoshy (2015) highlights the potential of dissolved gas analysis (DGA) for early fault detection in transformers, suggesting that advanced techniques can significantly aid in leak mitigation efforts.

The extreme environmental conditions in Saudi Arabia—characterized by high ambient temperatures that can reach up to 55°C and frequent sandstorms—further exacerbate these degradation mechanisms, leading to

premature failures and an increased frequency of oil leaks.

1.3 Importance of the Study

This study holds significant scientific and practical importance for several reasons:

- **Alignment with Saudi Vision 2030:** It supports the objectives of environmental sustainability and economic diversification outlined in the national vision.
- **Enhancement of Grid Reliability:** By addressing transformer oil leaks, the study aims to reduce unplanned outages and improve overall operational efficiency.
- **Mitigation of Environmental Impact:** It focuses on protecting local ecosystems and minimizing pollution,

thereby contributing to a healthier environment.

- Improvement of Economic Viability: The findings can lead to lower maintenance costs and extended lifespans for transformers, ultimately benefiting the economy.

1.4 Objectives of the Study

This study aims to achieve the following objectives:

1. Investigate Gasket Degradation Mechanisms: Analyze how the unique conditions of Saudi Arabia's arid climate contribute to the deterioration of gaskets used in transformers, identifying specific factors that accelerate degradation.
2. Evaluate Advanced Leak Detection Methods: Assess the effectiveness of modern leak detection technologies,

such as Internet of Things (IoT) sensors and Dissolved Gas Analysis (DGA), in identifying and monitoring oil leaks in real-time.

3. Explore Sustainable Gasket Materials and Maintenance

Practices: Research and propose innovative, environmentally friendly gasket materials and maintenance strategies that can reduce the occurrence of oil leaks and enhance the longevity of transformer components.

4. Assess Economic and Environmental Impact: Analyze

the potential economic benefits and environmental implications of implementing advanced gasket technologies and sustainable practices, highlighting their value in reducing maintenance costs and minimizing

ecological damage.

By addressing these objectives, the study seeks to contribute valuable insights that can enhance transformer reliability while promoting sustainability in the energy sector

.1.5 Study Questions

Main Question: What are the key factors influencing the performance and sustainability of gaskets in power transformers operating in Saudi Arabia's dry climate?

1. What are the major causes of gasket degradation in power transformers operating in Saudi Arabia's dry climate?

2. How effective are advanced leak detection methods, such as IoT sensors and Dissolved Gas Analysis (DGA), in identifying and preventing transformer oil leaks?
3. What are the potential benefits and challenges associated with the adoption of advanced gasket materials, such as nanocomposites and smart gaskets, within Saudi Arabia's power transmission infrastructure?
4. What policy recommendations can be proposed to enhance sustainable transformer management practices and reduce oil leaks in the Kingdom of Saudi Arabia?

1.6 Study Assumptions

Study Assumptions

1. Gasket failure significantly contributes to transformer oil leaks in Saudi Arabia.
2. The use of advanced gasket materials and leak detection techniques can improve the sustainability of transformers.
3. Data obtained from laboratory experiments and field tests will reliably represent real-world conditions.

Study Terminology

Key Terms:

- Transformer Sustainability: The ability of transformers to operate efficiently and reliably over the long term with

minimal negative impacts on the environment and economy. This includes reducing failures, extending operational life, and minimizing the need for costly maintenance and disposal of contaminated oils.

- Power Transmission Projects: Projects related to the transmission of electrical energy from production sources to distribution and consumption centers through high-voltage electrical networks.

- Kingdom of Saudi Arabia: The geographical and regulatory context of the study, considering the environmental and operational conditions specific to its power transmission networks.

- **Advanced Sealing Gasket Technologies:** The latest innovations in the design, materials, and manufacturing of sealing gaskets used in transformers, aimed at improving their performance and effectively preventing oil leaks.
- **Sealing Gaskets:** Flexible components used to seal gaps between different parts of the transformer, including pipe joints and tank covers, to prevent the leakage of insulating and cooling oil.
- **Leak Detection Methods:** Procedures and techniques used to identify the presence, location, and size of oil leaks from transformers.
- **Oil Leakage Reduction:** Efforts and measures taken to reduce or prevent the leakage of insulating and cooling oil

from transformers, aimed at improving operational efficiency and environmental safety.

- Oil Leakage: The unintended release of insulating and cooling oil from transformers into the surrounding environment.

Study Variables

Dependent Variable:

- Transformer Sustainability: Measured by a set of indicators, including:
 - Failure Rate: The number of times transformers fail or require major maintenance over a specified period.

- Mean Time Between Failures (MTBF): The average time period that transformers operate normally between each failure.
- Maintenance Costs: The total costs associated with the maintenance and repair of transformers.
- Operational Lifespan: The duration for which a transformer can operate efficiently before needing replacement.
- Quantity of Leaked Oil: The volume of oil lost due to leaks over a specified period.
- Environmental Impact: The negative effects of oil leaks on the surrounding environment.

Independent Variables:

- Advanced Sealing Gasket Technologies:

- Gasket Material Type: (e.g., high-performance synthetic rubber, composite materials, etc.).

- Gasket Design: (e.g., multi-layer design, optimized sealing design, etc.).

- Installation Techniques: (e.g., using precise installation tools, standardized installation procedures, etc.).

- Integrated Monitoring Systems: (e.g., pressure and temperature sensors integrated into the gaskets).

- Leak Detection Methods:

- Early Detection Techniques: (e.g., gas sensors, acoustic sensors, thermal imaging).

- Localized Detection Techniques: (e.g., revealing dyes, fluorescent materials).

- Continuous Monitoring Systems: (e.g., automated systems that continuously monitor oil levels and pressure).

- Periodic Inspection Protocols: (e.g., regular visual and technical inspection procedures).

Chapter Two

Previous Studies

Previous Studies

Local Studies

Al-Taher Study (2018): The study showed that renewable energies contribute to achieving sustainable development, as they are energy acquired from nature, constantly renewed, inexhaustible, and non-polluting.

Ali Study (2018): The study clarified the existence of a positive relationship between renewable energy production and economic sustainability in Egypt in the long term, and that renewable energy affects economic sustainability.

Mohammed and Al-Rashidi Study (2022): The research results indicated that the use of solar renewable energy in the production of biofuel plants (Jojoba) achieves financial and environmental feasibility in the Red Sea Governorate.

Foreign Previous Studies

Hannan et al. Study (2021)

Study Objectives: Studying the impact of using renewable energy and artificial intelligence in achieving the Sustainable Development Goals.

Independent Variable: Use of renewable energy and artificial intelligence.

Dependent Variable: Sustainable development.

Research Methodology: The study relied on the descriptive analytical approach.

Key Findings and Recommendations:

The results concluded that renewable energy has a positive impact towards achieving 75 targets of the Sustainable Development Goals, while it may negatively affect the achievement of 27 targets.

Artificial intelligence can help in enabling renewable energy to achieve 42 targets out of 169 targets.

With the current accelerating growth of the share of renewable energy and the development of artificial intelligence, this should be accompanied by a regulatory vision and the regulation of the technology necessary to cover more goals in the future.

Behera Sethi Study (2023)

Study Objectives: *Studying the impact of the role of renewable energy, green finance, and policy stability in achieving Goal 13 of the Sustainable Development Goals, an empirical view from emerging economies.*¹

Independent Variable: The role of renewable energy, green finance, and policy stability.

Dependent Variable: Sustainable development.

Research Methodology: The study relied on the descriptive analytical approach.

Key Findings and Recommendations:

The results concluded that renewable energy consumption and green finance significantly reduce carbon dioxide emissions.

A positive effect of political stability on carbon dioxide emissions was observed.

The study recommended that emerging economies need a stronger political system to promote green finance and renewable energy consumption to achieve sustainable development goals by addressing climate change policy.²

Theoretical Framework

Concept of Sustainability in the Energy Sector:

Definition of sustainability and its different dimensions (economic, environmental, social).

Importance of sustainability in the energy transmission sector and its impact on sustainable development in the Kingdom of Saudi Arabia.

Global and local trends towards sustainability in energy asset management.

Power Transformers and Their Vital Role in Energy Transmission Networks:

Explanation of the operating principle of power transformers and their different types used in transmission networks.

Strategic importance of transformers in ensuring the stability and efficiency of energy transmission networks.

Challenges and risks associated with the operation and maintenance of transformers.

Oil Leakages in Transformers: Causes and Effects:

Analysis of the main reasons for oil leakages in transformers (manufacturing defects, corrosion, harsh operating conditions, etc.).

Clarification of the environmental, economic, and operational effects of oil leakages (soil and water pollution, oil loss, fire hazards, operational shutdowns, maintenance costs).

Regulatory frameworks and environmental standards related to handling transformer oils and their leakages in the Kingdom of Saudi Arabia.

Advanced Heater Gasket Technologies for Transformers:
Review of traditional heater gasket types used in transformers and their weaknesses.

Analysis of advanced heater gasket technologies (modern materials, improved designs, innovative sealing techniques).

Evaluation of the effectiveness and reliability of these advanced technologies in preventing oil leakages and extending the lifespan of transformers.

Methods of Leakage Detection in Transformers:
Review of traditional methods for detecting oil leakages (visual inspection, manual tests).

Analysis of advanced leakage detection technologies (remote sensors, thermal imaging, chemical oil analysis techniques).

Comparison between the effectiveness, accuracy, and cost of different leakage detection methods.

The Role of Predictive Maintenance in Reducing Oil Leakages:
Explanation of the concept of predictive maintenance and its importance in energy asset management.

Clarification of how early fault detection technologies (including leakages) can be used to reduce leakage incidents.

Review of tools and techniques used in the predictive maintenance of transformers.

Best Practices in Transformer Oil Management:

Analysis of the transformer oil lifecycle (filling, operation, treatment, regeneration, disposal).

Review of best practices in handling transformer oils to ensure their safety and reduce environmental risks.

Importance of periodic testing of transformer oils for the early detection of potential problems.

Future Trends in Sustainable Transformer Technology:

Review of modern innovations in transformer design and manufacturing to enhance their sustainability (oil alternative materials, high-efficiency transformers, compact designs).¹

Analysis of the potential for applying these future trends in energy transmission projects in the Kingdom of Saudi Arabia.

Regulatory Framework and Incentives to Promote Transformer Sustainability in the Kingdom of Saudi Arabia:

Analysis of government policies and regulations related to the energy sector and environmental protection in the Kingdom.

Review of incentives and facilities provided for adopting sustainable technologies in energy projects.

Identification of the challenges and opportunities related to the implementation of these policies and incentives.

The Concept of Sustainability in the Energy Sector:

Definition of Sustainability and its Different Dimensions

(Economic, Environmental, Social):

Definition: Sustainability, at its core, is *the ability to meet the needs of the present without compromising the ability of future generations to meet their own needs.*¹ This simple definition goes beyond the environmental aspect to include other interconnected dimensions.

Different Dimensions:

Economic Dimension: Focuses on sustainable economic growth that does not deplete natural resources or lead to environmental degradation in the long term. In the energy sector, this means achieving energy efficiency, developing economically viable renewable energy sources, and creating sustainable job opportunities in this sector. It also includes reducing long-term operational and maintenance costs by adopting sustainable technologies.

Environmental Dimension: Relates to preserving the environment, protecting natural resources, and reducing the negative impacts of human activities on the planet. In the energy sector, this means reducing greenhouse gas emissions, limiting pollution from energy production and transmission (such as soil and water pollution from oil spills), and preserving biodiversity.

Social Dimension: Focuses on achieving justice, equality, and well-being for all members of society. In the energy sector, this means ensuring access to affordable energy services for all, providing safe and healthy working environments for workers in the sector, and involving local communities in energy projects while respecting their rights and needs.

Importance of Sustainability in the Energy Transmission Sector and its Impact on Sustainable Development in the Kingdom of Saudi Arabia:

Importance in the Energy Transmission Sector: The energy transmission sector is a vital link between energy production sources and consumers. Applying sustainability principles in this sector is of utmost importance for the following reasons:

Reducing Losses: Unsustainable transmission networks may lead to significant energy loss during transmission, which consumes additional resources and increases emissions.

Enhancing Efficiency: Adopting sustainable technologies and practices can improve the efficiency of transmission networks and reduce energy and resource consumption.

Lowering Environmental Risks: Reducing oil and other harmful material leaks protects the environment and reduces treatment and cleanup costs.

Increasing Asset Lifespan: Sustainable maintenance and the use of durable technologies can extend the life of transformers and other equipment, reducing the need for frequent replacements.

Improving Reliability and Stability: Sustainable transmission networks are more reliable and less prone to outages, ensuring a continuous supply of energy.

Impact on Sustainable Development in the Kingdom of Saudi Arabia: The Kingdom of Saudi Arabia is increasingly focused on

achieving sustainable development in various sectors, including the energy sector. Applying sustainability in the energy transmission sector directly contributes to achieving the Kingdom's sustainable development goals through:

Diversifying Energy Sources: Paves the way for the efficient integration of renewable energy sources into the grid.

Protecting the Environment: Reduces the negative environmental impacts of the energy sector, in line with the Kingdom's Vision 2030.

Promoting Sustainable Economic Growth: Creates investment opportunities and new jobs in the field of sustainable technologies and practices.

Improving Quality of Life: Ensures a reliable and clean energy supply for citizens and residents.

Global and Local Trends Towards Sustainability in Energy Asset Management:

Global Trends: The global energy sector is witnessing a shift towards sustainability driven by increasing awareness of climate change, resource scarcity, and regulatory pressures. Key global trends include:

Transition to Renewable Energy Sources: Increasing reliance on solar, wind, hydro, and other clean energy sources.

Increasing Energy Efficiency: Adopting technologies and practices that reduce energy consumption at all stages of production, transmission, and consumption.

Developing Smart Grids: Using technology to improve the management of energy networks and increase their reliability and efficiency.

Circular Economy: Adopting economic models that aim to reuse and recycle materials and components to reduce waste and resource depletion.

Focus on Sustainability in Asset Management: Integrating sustainability principles into the design, procurement, operation, and maintenance of energy assets.

Local Trends in the Kingdom of Saudi Arabia: The Kingdom of Saudi Arabia has adopted Vision 2030, which places great emphasis on sustainability in the energy sector. Key local trends include:

Saudi Green Initiative: Aims to increase reliance on renewable energy and reduce carbon emissions.

Massive Renewable Energy Projects: Significant investments in solar and wind energy projects.

Energy Efficiency Programs: Initiatives to rationalize energy consumption in various sectors.

Investment in Clean Technologies: Supporting research and development and adopting technologies that reduce the environmental impacts of the energy sector.

Focus on Developing Sustainable Infrastructure: Including energy transmission networks.

Electrical Transformers and Their Vital Role in Energy Transmission Networks:

Explanation of the Working Principle of Electrical Transformers and Their Different Types Used in Transmission Networks:

Working Principle: Electrical transformers rely on the principles of electromagnetic induction to transfer electrical energy between two or more circuits at different voltages without a direct electrical connection between them. A transformer mainly consists of two coils of wire (the primary coil and the secondary coil) wound around an iron core. When an alternating current passes through the primary coil, it produces an alternating magnetic field that penetrates the iron core and induces an alternating voltage in the secondary coil. The voltage ratio between the two coils is proportional to the ratio of the number of turns in each coil.

Different Types Used in Transmission Networks: There are different types of transformers used in energy transmission networks, classified based on several factors such as:

Voltage Level:

Step-up Transformers: Used in power generation plants to raise the electrical voltage to very high levels for efficient transmission over long distances.

Step-down Transformers: Used in distribution substations to lower the electrical voltage to levels suitable for industrial, commercial, and residential use.

Insulation Type:

Oil-immersed Transformers: Use oil as an insulator and cooling medium. They are the most common in high-capacity transmission networks.

Dry-type Transformers: Use air or solid materials as insulation. They are often used in indoor or relatively low-capacity applications.

Number of Phases:

Single-phase Transformers: Used in specific applications or in building three-phase transformer banks.

Three-phase Transformers: The most commonly used in energy transmission and distribution networks.

Design and Construction: There are different designs such as shell-type transformers and core-type transformers.

Strategic Importance of Transformers in Ensuring the Stability and Efficiency of Energy Transmission Networks:

Enabling Long-Distance Transmission: Step-up transformers allow for the efficient transmission of electrical energy over long distances by reducing energy loss due to wire resistance (as the loss is inversely proportional to the square of the voltage).

Facilitating Interconnection Between Different Voltage Systems:

Transformers allow for the connection of transmission and distribution networks with different voltage levels, enabling the integration of energy sources and meeting the needs of different consumers.

Ensuring Voltage Stability: Transformers with voltage regulators help maintain a stable voltage level at distribution points regardless of load changes on the network.

Protecting Equipment: Isolation transformers separate high-voltage circuits from low-voltage circuits, providing protection for equipment and users.

Improving Network Efficiency: By transmitting energy at high voltages and reducing losses, transformers contribute to improving the overall efficiency of the energy transmission network.

Providing Flexibility in Network Design and Operation:

Transformers allow for the design of flexible and scalable transmission and distribution networks to meet the increasing energy needs.

Challenges and Risks Associated with the Operation and Maintenance of Transformers:

Challenges:

High Replacement Costs: High-capacity transformers are expensive assets, and their replacement represents a significant financial burden.

Long Maintenance Downtime: Some maintenance work requires long operational downtime, which may affect the continuity of energy supply.

Harsh Operating Conditions: Transformers in some regions are exposed to harsh operating conditions such as high temperatures, humidity, and dust, which increases the likelihood of failures.

Deterioration of Insulation Materials: Over time and exposure to heat and electrical stress, the insulation materials inside the transformer deteriorate, increasing the risk of failures.

Need for Specialized Maintenance: Transformer maintenance requires specialized expertise and equipment.

Risks:

Oil Leaks: As will be detailed in the next section, oil leaks are one of the most serious problems facing transformers due to their environmental, economic, and safety impacts.

Electrical Faults: Internal faults in the transformer (such as short circuits) can lead to significant damage or even explosion and fire.

High Temperature: Overloading or cooling problems can lead to high transformer temperatures, insulation degradation, and reduced lifespan.

Noise and Vibrations: Transformers can cause noise and vibrations that may affect the surrounding environment.

Oil Leaks in Transformers: Causes and Effects:

Analysis of the Main Causes of Oil Leaks in Transformers
(Manufacturing Defects, Corrosion, Harsh Operating Conditions, etc.):

Manufacturing Defects: Oil leaks may occur due to errors in the transformer manufacturing process, such as:

Loose Welds: Weak or incomplete welds in the transformer tank or at pipe and valve connection points.

Defective Sealing Materials: Using low-quality or unsuitable sealing materials (gaskets) for the operating conditions.

Improperly Tightened Screws or Bolts: Failure to properly tighten various parts may lead to gaps allowing oil leakage.

Corrosion: Over time, the transformer tank, pipes, and valves can corrode due to environmental factors (such as humidity and salts) or chemical reactions with the oil. Corrosion leads to weakening of the metal and the appearance of holes or cracks.

Harsh Operating Conditions: Abnormal operating conditions can contribute to oil leaks, such as:

Overloading: Operating the transformer at loads higher than its design capacity leads to an increase in its temperature and expansion of the oil and components, increasing pressure on sealing points.

Mechanical Vibrations: Vibrations from nearby equipment or external conditions can lead to loosening of connections and damage to gaskets.

Large Temperature Variations: Repeated expansion and contraction of components due to temperature changes can stress and damage sealing materials.

Accidents and Physical Damage: Shocks or collisions that transformers are subjected to during transportation or operation can damage the tank or pipes and cause leaks.

Deterioration of Sealing Materials (Gaskets): Gaskets lose their elasticity and effectiveness over time due to exposure to heat, oil, and oxidation, leading to their inability to provide a tight seal.

Maintenance Errors: Leaks may occur due to errors during maintenance operations, such as failure to properly tighten connections after maintenance.

Clarification of the Environmental, Economic, and Operational Effects of Oil Leaks (Soil and Water Pollution, Oil Loss, Fire Hazards, Operational Downtime, Maintenance Costs):

Environmental Effects:

Soil Pollution: Oil seeps into the soil and pollutes it, negatively affecting microorganisms and plants. Cleaning up contaminated soil can take time, effort, and significant costs.

Groundwater and Surface Water Pollution: If leaked oil reaches groundwater sources or rivers and lakes, it pollutes them,

making them unsuitable for human and animal use and affecting aquatic ecosystems.

Harm to Wildlife: Leaked oil can harm animals and birds that come into contact with it or ingest it.

Economic Effects:

Oil Loss: Transformer oil is an expensive substance, and its leakage leads to direct financial loss.

Cleanup and Treatment Costs: Treating soil and water contaminated with oil requires significant costs.

Maintenance and Repair Costs: Repairing leaks and replacing damaged parts increases maintenance costs.

Fines and Penalties: Regulatory authorities may impose fines and penalties on companies that cause environmental pollution as a result of oil leaks.

Operational Downtime: Repairing leaks may require shutting down the transformer, leading to economic losses resulting from power outages.

Operational Effects:

Unplanned Operational Downtime: Large leaks can lead to a dangerously low oil level in the transformer, necessitating its shutdown to avoid damage.

Reduced Cooling and Insulation Efficiency: Oil shortage reduces the efficiency of transformer cooling and insulation, increasing the risk of overheating and electrical faults.

Increased Fire Hazards: Transformer oil is flammable, and its leakage increases the risk of fires, especially in the event of an electrical spark.

Deterioration of Transformer Condition: Continuous leaks can lead to the deterioration of the transformer's condition and reduce its lifespan.

Advanced Sealing Gasket Technologies for Transformers:

Review of Traditional Sealing Gasket Types Used in

Transformers and Their Weaknesses:

Traditional Gasket Types:

Cork Gaskets: Were widely used in the past due to their flexibility and compressibility.

Paperboard Gaskets: An economical option but less durable and resistant to oil and heat.

Conventional Rubber Gaskets: Such as nitrile rubber (NBR) and natural rubber, offer good flexibility but may degrade over time when exposed to heat, oil, and chemicals present in transformer oil.

Asbestos Gaskets: Were used for their high resistance to heat and pressure, but their use has been discontinued due to known health risks.

Weaknesses of Traditional Gaskets:

Degradation Due to Heat: Transformers are exposed to high temperatures during operation, causing traditional gaskets to harden, crack, and lose their sealing ability over time.

Reaction with Transformer Oil: Some traditional materials can react with the chemical components present in transformer oil, leading to their degradation, swelling, or shrinkage and loss of sealing properties.

Loss of Elasticity Over Time: Traditional materials lose their elasticity and ability to compress effectively over time and exposure to operating conditions, allowing leaks to occur.

Sensitivity to Pressure: Some traditional gaskets may not withstand the high pressures generated inside the transformer, especially under overload conditions or sudden pressure changes.

Corrosion and Fragmentation: Some traditional materials can corrode or fragment over time, leading to loss of seal and contamination of the oil with particles.

Difficulty in Installation and Tightening: It may be difficult to install some traditional gaskets with a completely tight seal, increasing the likelihood of leaks from the beginning.

Analysis of Advanced Sealing Gasket Technologies (Modern Materials, Improved Designs, Innovative Sealing Techniques):

Modern Materials:

Fluorocarbon Rubber (Viton/FKM): Features excellent resistance to high heat, oils, and chemicals, making it an ideal choice for transformer gaskets exposed to harsh operating conditions.

Silicone Rubber: Offers good heat resistance and flexibility over a wide temperature range, as well as resistance to ozone and ultraviolet radiation.

Ethylene Propylene Diene Monomer (EPDM): Features good resistance to heat, ozone, and non-oily chemicals, and has good electrical insulation properties.

Polytetrafluoroethylene (PTFE/Teflon): Features a low coefficient of friction and excellent chemical and thermal resistance, and is often used as an additional layer in composite gaskets to improve sealing properties.

Composite Materials: Consist of a mixture of two or more materials to achieve enhanced performance properties, such as

combining the load-bearing resistance of one material with the oil resistance of another.

Improved Designs:

Multi-Lip Designs: Provide multiple sealing points to increase the effectiveness of leak prevention even if some damage occurs to one of the lips.

Self-Energizing Designs: Use fluid pressure or mechanical force to increase sealing force with increasing internal pressure.

Molded Edge Designs: Provide a more precise and compatible sealing surface with mating surfaces.

Use of Bonded Metal Rings: Enhance the strength of the gasket and prevent over-compression.

Innovative Sealing Techniques:

Mechanical Seals: Provide a more reliable and durable seal compared to traditional gaskets, especially in high-pressure and rotating applications (although their use in transformer bushings may be limited).

Injection Sealing Techniques: Allow for the injection of sealant materials into leak areas without the need for complete disassembly of equipment.

Use of Sealants and Adhesives: Specialized adhesives can be used to enhance sealing in connection areas.

Evaluation of the Effectiveness and Reliability of These Advanced Technologies in Preventing Oil Leaks and Extending the Lifespan of Transformers:

Effectiveness in Preventing Leaks: Gaskets made from modern materials and improved designs have a significantly higher ability to prevent oil leaks compared to traditional gaskets. Their resistance to heat, oils, and chemicals ensures that sealing properties are maintained for a longer period. Multi-lip and self-energizing designs provide additional protection against leakage even under difficult conditions.

Reliability: Advanced materials feature higher durability and a longer lifespan, reducing the likelihood of gasket failure and leaks. Their ability to withstand harsh operating conditions increases the reliability of the sealing system in general.

Extending the Lifespan of Transformers: By preventing oil leaks, these advanced technologies help maintain the appropriate oil level inside the transformer, which is essential for its effective cooling and insulation. This reduces the risk of overheating and electrical faults, thus contributing to extending the transformer's lifespan and reducing the need for costly maintenance and repairs. In addition, preventing environmental pollution with oil

reduces regulatory risks and costs associated with cleanup and treatment.

Methods for Detecting Leaks in Transformers:

Review of Traditional Methods for Detecting Oil Leaks (Visual Inspection, Manual Tests):

Visual Inspection:

Description: This is the basic and most common method for detecting leaks. Technicians inspect the transformer surface, tank, connections, pipes, and valves for any signs of oil leakage, such as oil stains, traces of oil flow, or wet or shiny areas.

Advantages: Simple, quick, and does not require specialized equipment. Can detect obvious and large leaks.

Disadvantages: Relies on the technician's experience and observation skills. May not detect small or slow leaks, or leaks hidden in hard-to-reach areas. It also does not provide quantitative information about the size or exact location of the leak in some cases.

Manual Tests:

Surface Wipe Test: Suspected areas are wiped with a cloth or paper, and examined for traces of oil.

Pressure Test: The pressure inside the transformer tank is increased, and any drop in pressure indicating a leak is

monitored. Soap foam can be used to visually identify the leak location at weak points.

Oil Level Monitoring: Periodic monitoring of the oil level in the transformer tank. A continuous drop in the level indicates a leak.

Advantages: Can help confirm the presence of a leak not clearly visible to the naked eye and identify potential leak areas. The pressure test can be effective in detecting even small leaks.

Disadvantages: The pressure test requires shutting down the transformer and may be risky if not performed correctly. Oil level monitoring may not detect very slow leaks until a long period has passed. Manual tests are often inaccurate and time-consuming.

Analysis of Advanced Techniques for Detecting Leaks (Remote Sensors, Thermal Imaging, Chemical Analysis Techniques of Oil):

Remote Sensors:

Description: Use specialized sensors to detect the presence of oil or changes in the surrounding environment that may indicate a leak, without the need for direct contact with the transformer surface. These devices may include hydrocarbon gas sensors or sensors for excess moisture in the surrounding soil.

Advantages: Can continuously monitor large or hard-to-reach areas. Can provide early warning upon leak detection.

Disadvantages: May be expensive to install and maintain. Their accuracy may be affected by other environmental conditions.

May require integration with other monitoring systems to accurately locate the leak.

Thermal Imaging (Infrared Thermography):

Description: Uses thermal cameras to detect differences in the surface temperature of the transformer. The presence of leaked oil can indicate a change in the thermal properties of the affected area, appearing as a spot with a different temperature in the thermal image.

Advantages: A quick and non-destructive method for detecting leaks. Can cover large areas and identify potential leak areas with relative accuracy. Can be used while the transformer is in operation.

Disadvantages: Its accuracy may be affected by factors such as weather conditions and solar radiation. May require trained technicians to analyze thermal images correctly. May not be effective in detecting very small or slow leaks.

Chemical Analysis Techniques of Oil:

Description: Involves taking samples of the soil or water surrounding the transformer and chemically analyzing them to detect the presence of transformer oil components. Samples of the transformer oil itself can also be analyzed to detect any abnormal changes that may indicate an internal or external leak.

Advantages: Can provide conclusive evidence of oil contamination. Can help identify the source and type of leak.

Disadvantages: Requires time and effort to collect samples and perform analyses. May not provide immediate information about the leak location. Analysis of the transformer oil itself may only indirectly reveal external leaks (through a drop in oil level or changes in its properties).

Best Practices in Transformer Oil Management:

Analysis of the Transformer Oil Lifecycle (Filling, Operation, Treatment, Regeneration, Disposal):

Filling:

Description: This is the initial stage where the transformer is filled with the appropriate quantity and type of insulating oil according to the manufacturer's specifications.

Best Practices:

Use new, high-quality oils that meet standard criteria and specifications.

Ensure the oil is clean and free of moisture, gases, and solid particles before filling.

Follow proper filling procedures to avoid introducing air or moisture into the transformer.

Record the type and quantity of oil used and the filling date.

Operation:

Description: This is the period when the transformer is in operation and under the influence of electrical and thermal conditions.

Best Practices:

Periodically monitor the oil level and temperature.

Avoid overloading the transformer, which may lead to increased oil temperature and degradation.

Ensure the transformer's cooling system is working efficiently.

Conduct periodic inspections for early detection of any leaks or other problems.

Treatment:

Description: Over time, transformer oil can degrade due to moisture absorption, oxidation, and the accumulation of solid particles and dissolved gases. Treatment involves procedures to remove these contaminants and improve the oil's properties.

Best Practices:

Conduct periodic oil tests to determine its condition and the need for treatment.

Use specialized equipment to purify the oil from solid particles, moisture, and dissolved gases (such as filtration, drying, and degasification).

Absorbent materials can be used to remove some acidic products resulting from oxidation.

Treatment operations should be performed by trained technicians and according to recommended procedures.

Regeneration/Reclamation:

Description: In some cases, used transformer oil can be regenerated to significantly restore its original properties. This process involves removing acidic oxidation products and other contaminants using chemicals or advanced physical processes.

Best Practices:

Assess the oil condition to determine if regeneration is economically and technically feasible.

Use approved and effective regeneration techniques.

Ensure the regenerated oil meets standard specifications before returning it to service.

Regeneration can be a sustainable and economical option compared to complete oil replacement.

Disposal:

Description: When the oil becomes unsuitable for use or regeneration, it must be disposed of safely and in an environmentally responsible manner.

Best Practices:

Follow local and international regulations and laws related to the disposal of waste oils.

Store used oil in appropriate containers to prevent leakage and contamination.

Hand over used oil to specialized companies for recycling or proper disposal of hazardous waste.

Avoid dumping used oil into sewers or the environment.

Explore options for recycling used oil whenever possible.

Review of Best Practices in Handling Transformer Oils to Ensure Their Safety and Reduce Environmental Risks:

Safe Storage:

Store new and used oils in designated, well-ventilated areas away from ignition sources and heat.

Use tightly sealed, corrosion-resistant, and leak-proof containers.

Clearly label containers to identify the type and condition of the oil (new/used).

Provide spill control equipment (such as absorbent materials and barriers) in storage areas.

Safe Handling:

Use appropriate transfer equipment (such as pumps and drums) to avoid spills.

Train personnel on safe oil handling procedures.

Wear appropriate personal protective equipment (such as gloves and safety glasses).

Have emergency plans in place to deal with spills.

Leak Prevention:

Conduct periodic inspections of transformers and oil-related equipment for early detection of any signs of leakage.

Maintain and repair any leaks immediately upon detection using appropriate materials and techniques.

Use high-quality gaskets and sealing materials.

Follow proper tightening procedures when performing maintenance.

Responsible Disposal:

Do not dispose of used oils into the environment or sewers.

Contract with licensed companies for hazardous waste disposal or recycling of used oils.

Maintain records of oil disposal operations.

Training and Awareness:

Provide comprehensive training to personnel responsible for handling transformer oils on potential hazards, safety procedures, and best practices.

Raise awareness about the importance of proper transformer oil management for environmental protection.

Importance of Periodic Testing of Transformer Oils in Early Detection of Potential Problems:

Assessing Oil Condition: Periodic tests help determine the condition of the oil and monitor any deterioration in its properties

(such as viscosity, dielectric strength, acidity, moisture content, presence of dissolved gases, and solid particles).

Early Detection of Faults: Changes in oil properties can indicate the presence of problems inside the transformer in their early stages (such as excessive overheating, partial discharge, and corrosion of internal parts). Early detection allows for corrective actions to be taken before the problem worsens and major failures occur.

Determining the Need for Treatment or Regeneration: Test results determine whether the oil needs treatment to remove contaminants or regeneration to restore its properties, thus extending the oil's lifespan and reducing the need for replacement.

Improving Transformer Reliability: Maintaining oil quality ensures optimal insulation and cooling performance of the transformer, reducing the risk of failures and improving its reliability and stability.

Reducing Long-Term Maintenance Costs: Early detection of problems allows for simple and inexpensive repairs instead of dealing with major failures that require more time, effort, and higher costs.

Ensuring Environmental Safety: Monitoring the oil condition helps detect any potential contamination (such as the presence of heavy metals or harmful compounds) and take necessary measures to prevent leaks and environmental pollution.

Compliance with Standards and Regulations: Many standards and regulations require periodic testing of transformer oils to ensure operational safety and environmental protection.

Future Trends in Sustainable Transformer Technology:
Review of Modern Innovations in the Design and Manufacturing of Transformers to Enhance Their Sustainability (Alternative Materials to Oil, High-Efficiency Transformers, Compact Designs):

Alternative Dielectric Fluids:

Vegetable Oils: Feature high biodegradability and are non-toxic, with a higher flash point than traditional mineral oils, increasing safety.

Synthetic Esters: Offer good electrical and thermal performance and are biodegradable to a certain extent, also being less toxic than mineral oils.

Silicone-Based Fluids: Feature high heat and flame resistance and good chemical stability.

Dry-Type Transformers: Use air or solid materials (such as vacuum-impregnated resins) as insulation, completely eliminating the risk of oil leaks and reducing fire hazards.

High-Efficiency Transformers:

Use of Low-Loss Core Materials: Such as high-quality silicon steel or nanomaterials that reduce losses in the iron core.

Optimized Winding Designs: To reduce electrical current resistance and thus reduce losses in the windings.

Advanced Cooling Techniques: To improve heat transfer efficiency and reduce the energy required for cooling.

Smart Transformers: Include sensors and control systems to monitor their performance and continuously improve their efficiency based on operating conditions.

Compact Designs:

Smaller and Lighter Transformers: Reduce material usage and facilitate transportation and installation.

Modular Designs: Allow for easy expansion, maintenance, and replacement.

Integration of Multiple Functions: Integrating additional components such as circuit breakers and protection devices within the transformer structure to reduce space and costs.

Analysis of the Applicability of These Future Trends in Energy Transmission Projects in the Kingdom of Saudi Arabia:

Alternative Materials to Oil:

Opportunities: Can contribute to reducing the environmental and safety risks associated with traditional mineral oils, especially in environmentally sensitive or densely populated areas. Vegetable oils may be an attractive option given the availability of some raw materials locally.

Challenges: Some alternatives may be more expensive or require modifications in transformer design or maintenance procedures. Their performance in the Kingdom's hot climate may need to be evaluated.

High-Efficiency Transformers:

Opportunities: Align with the Kingdom's efforts to rationalize energy consumption and reduce losses in transmission networks. Can lead to significant savings in long-term operating costs.

Challenges: Their initial cost may be higher than traditional transformers. Need to adopt standards and policies that encourage the use of high-efficiency transformers.

Compact Designs:

Opportunities: Can reduce the need for installation space and facilitate the construction of substations, especially in crowded urban areas.

Challenges: May require new standard designs and staff training on installation and maintenance procedures.

Dry-Type Transformers:

Opportunities: Provide a safe and environmentally friendly solution in some applications, especially indoors or near sensitive areas.

Challenges: May be limited in their capacities compared to oil-immersed transformers for high-voltage and high-capacity energy transmission applications.

Regulatory Framework and Incentives to Promote Transformer Sustainability in the Kingdom of Saudi Arabia:

Analysis of Government Policies and Regulations Related to the Energy Sector and Environmental Protection in the Kingdom:

Vision 2030: Includes clear goals for environmental sustainability, diversification of energy sources, and rationalization of consumption, creating a general context for promoting transformer sustainability.

Energy Efficiency Policies: There may be regulations or initiatives that encourage the use of high-efficiency equipment in the energy sector, including transformers.

Environmental Regulations: Laws and regulations related to the protection of soil and water from pollution caused by hazardous materials such as transformer oils, and regulating their disposal processes.

Standards and Specifications: There may be standards that specify the quality of transformer oils and the environmental safety requirements for new and used transformers.

Regulatory Authorities: Analysis of the role of government bodies responsible for the energy and environment sectors in setting and implementing these policies and regulations.

Review of Incentives and Facilities Provided for Adopting Sustainable Technologies in Energy Projects:

Financial Support and Subsidies: The government or investment funds may offer financial incentives or subsidies to companies

that invest in sustainable technologies in the energy sector, such as high-efficiency transformers or environmentally friendly alternatives to mineral oils.

Tax Incentives: There may be tax reductions or exemptions for projects that adopt sustainable solutions.

Research and Development Programs: Government or private support for research and development in the field of sustainable transformer technology.

Government Initiatives: Promotional programs or campaigns to encourage the adoption of sustainable practices in the energy sector.

Public-Private Partnerships: Joint initiatives to finance and implement sustainable energy projects.

Identifying the Challenges and Opportunities Related to the Application of These Policies and Incentives:

Challenges:

Initial Cost: Sustainable technologies may be more expensive initially compared to traditional solutions.

Awareness and Knowledge: There may be a lack of awareness and knowledge about the latest sustainable technologies and their benefits.

Existing Infrastructure: It may be difficult or costly to integrate new technologies into the existing infrastructure of energy transmission networks.

Implementation and Oversight: Ensuring the effective implementation of policies and regulations and oversight of compliance may be challenging.

Resistance to Change: There may be resistance from some parties to adopting new practices.

Opportunities:

Achieving National Sustainability Goals: Contributes to achieving the Kingdom's Vision 2030 and its environmental and economic goals.

Reducing Long-Term Costs: High efficiency and increased reliability can lead to significant savings in operating and maintenance costs.

Promoting Innovation and Economic Growth: Creates new opportunities for research and development and industries related to sustainable technologies.

Improving Reputation and Corporate Image: Adopting sustainable practices enhances the reputation of companies and attracts investors and customers interested in the environment.

Compliance with Future Regulations: Early preparation for stricter environmental regulations in the future.

Conclusion:

The study of promoting transformer sustainability in energy transmission projects in the Kingdom of Saudi Arabia, with a special focus on advanced sealing gasket technologies and leak detection methods to reduce oil leaks, derives its importance from the vital role that these transformers play in ensuring the stability and efficiency of energy transmission networks, and the significant environmental, economic, and operational impacts resulting from oil leaks.

The current theoretical framework has reviewed the basic concepts of sustainability in the energy sector, the importance of transformers in the energy infrastructure, and the causes and effects of oil leaks. Traditional and advanced technologies for sealing gaskets and leak detection methods have also been analyzed, highlighting the role of predictive maintenance and best practices in transformer oil management. In addition, future trends in sustainable transformer technology and the relevant regulatory framework and incentives in the Kingdom of Saudi Arabia have been explored.

Through this integrated theoretical framework, it becomes clear that adopting advanced technologies and sustainable practices is

not just an option, but an imperative for enhancing the efficiency and reliability of energy transmission networks in the Kingdom, reducing negative environmental impacts, and contributing to the achievement of the sustainable development goals of Vision 2030. Investing in advanced sealing gaskets and accurate and early leak detection methods, along with the sound management of transformer oils, represents crucial steps towards achieving long-term sustainability in this vital sector.

Chapter Three

Study Model

This study will employ a mixed-methods approach, combining qualitative and quantitative data analysis. The model integrates:

Literature review: Examining existing research on gasket degradation, leak detection, and transformer sustainability.

Laboratory experiments: Evaluating the performance of different gasket materials under controlled conditions.

Field tests: Assessing the effectiveness of IoT sensors in detecting leaks in operational transformers.

Case study analysis: Investigating gasket-related leaks in transformers manufactured by SPTC.

Statistical analysis and FEA: Analyzing data and simulating stress distribution in gaskets.

3.1 Mixed-Methods Approach

This research utilizes a mixed-methods approach, combining qualitative and quantitative data analysis to provide a comprehensive understanding of transformer gasket degradation and leak detection in Saudi Arabia.

Qualitative data is collected through cross-investigations with experienced engineers at SPTC and a thorough review of relevant literature on gasket materials, leak detection techniques, and transformer sustainability.

Quantitative: Quantitative data is collected through laboratory experiments and field tests, focusing on the performance of different gasket materials and leak detection methods.

3.2 Laboratory Experiments

Laboratory experiments were conducted to evaluate the mechanical and thermal properties of the RUBBER 6MM FLAT GASKET under simulated operating conditions.

These experiments focused on key performance indicators essential for reliable gasket function in power transformers.

Summary of Tests and Compliance

Test	Average Result	Requirement	Compliance
Elongation at break (%)	467.47	$\geq 250\%$ (min)	 Pass
Hardness (Shore A)	74	$70+5/-4$	 Pass
Compression Set (%)	14.51	$\leq 20\%$ (max)	 Pass
Aging – Tensile Strength (%)	+5.07	$\leq -30\%$ (max)	 Pass
Aging – Elongation (%)	-17.62	$\leq -30\%$ (max)	 Pass
Aging – Hardness Change	+1 point	$\leq +15$ points (max)	 Pass

Test	Average Result	Requirement	Compliance
Density (g/cm ³)	1.274	1.3 ±0.15	 Pass
*Calculated compression set average: $\frac{14.57+14.67+14.29}{3}$ = 14.51%.			

Tensile Testing: Tensile tests, performed according to ASTM D412–16, assessed the gasket's resistance to breaking under tension.

The average tensile strength of the NBR gasket material was 13.31 MPa. This result complies with the requirement of 10 MPa for transformer applications,

indicating that the gasket material is sufficiently strong to withstand the expected tensile forces in the field.


Property	Original (MPa)	Aged (MPa)	Change (%)
Average	12.69	13.31	+5.07%

Elongation at Break: Elongation at break tests, which are part of ASTM D412–16, measured the gasket's ability to stretch before breaking.

The NBR gaskets had an average elongation of 467.47%, greater than the required minimum of 250%. This high elongation indicates good flexibility and the ability of the gasket to conform to sealing surfaces, even under the

dimensional changes that can occur during transformer
operation.

Reading 1	Reading 2	Reading 3	Reading 4	Reading 5	Average
474.80 %	515.20 %	503.84 %	444.49 %	399.04 %	467.47 %



Accelerated Aging: Accelerated aging tests, following ASTM D573, were conducted to evaluate the long-term performance of the gasket material under elevated temperatures.

After 70 hours at 100°C, the NBR gaskets showed a 5.07% increase in tensile strength and a 17.62% decrease in elongation at break.

These results indicate that the gasket material tends to harden and become less flexible with thermal aging.

Property	Original (%)	Aged (%)	Change (%)
Average	467.47	381.36	-17.62%

Compression Set: Compression set tests, conducted by ASTM D395–18, measured the gasket's ability to maintain its sealing properties under compression for a long time.

The average compression set for the NBR gaskets was 14.51%, resulting in the requirement of being less than or equal to 20%. This indicates that the gasket material can effectively maintain a seal without significant permanent deformation.

Sample	Original Thickness (mm)	Final Thickness (mm)	Compression Set (%)
1	6.01	5.79	14.57

Sample	Original Thickness (mm)	Final Thickness (mm)	Compression Set (%)
2	6.00	5.78	14.67
3	6.04	5.82	14.29

Hardness: Hardness tests, performed according to ASTM

D2240–15, assessed the gasket's resistance to

indentation. The average hardness of the NBR gaskets


was 74 Shore A, complying with the requirement of 70 ± 5 .

This result indicates that the gasket material has the

appropriate hardness to resist deformation and maintain

sealing integrity.

Reading 1	Reading 2	Reading 3	Reading 4	Reading 5	Average
73	73	74	75	75	74



Density: Density measurements, following ASTM D792–
20, determined the gasket's density to be 1.274 g/cm³,
which falls within the acceptable range of 1.3±0.15 g/cm³.

This confirms that the gasket material meets the required density specifications.

Sample	Weight in Air (g)	Weight in Water (g)	Specific Gravity	Density (g/cm ³)
1	4.8994	1.0584	1.276	1.276
2	4.7367	1.0144	1.0144	1.0144
3	4.7448	1.0164	1.0164	1.0164

Overall, the laboratory experiments demonstrated that the RUBBER 6MM FLAT GASKET meets the performance requirements for transformer applications. However, it is important to note several variabilities observed in the elongation at break and accelerated aging tests, which

guarantee further investigation to ensure consistent performance and long life.

3.3 Field Testing

Field tests are conducted to evaluate the effectiveness of IoT-based sensors in detecting oil leaks in operational transformers.

IoT Sensors: IoT sensors are installed in few transformers, representing a various range of operating conditions and transformer types.

Data Collection: Data from the sensors is collected over a 6-month monitoring period, providing insights into real-world leak detection performance and the influence of environmental factors.

3.4 Case Study Analysis

A detailed case study analysis is conducted on transformers manufactured by SPTC, focusing on their documented history of gasket-related leaks.

This analysis helps identify specific challenges and opportunities for enhancing transformer sustainability within the Saudi Arabian environment.

3.5 Statistical Tools

Statistical tools and simulation techniques are used to analyze the collected data and validate the research hypotheses.

ANOVA: Analysis of variance (ANOVA) is used to compare the performance of different gasket materials under various operating conditions.

FEA: Finite element analysis (FEA) is employed to simulate stress distribution in gaskets under thermal cycling, providing insights into potential failure mechanisms.

Chapter Four: Data Analysis and Testing of Contrasts

4.1 Gasket Performance Under Stress

This section analyzes the laboratory test results for the

RUBBER 6MM FLAT GASKET (KHSPL2410017)

provided, focusing on the key performance indicators:

Tensile Strength: NBR gaskets showed an average tensile strength of 12.69 MPa, exceeding the 10 MPa requirement for transformer applications.

Elongation: NBR gaskets showed an elongation of 467.47%, significantly surpassing the 250% minimum specified for reliable sealing performance.

Compression Set: Compression set measurements for

NBR gaskets ranged from 14.57%, with moderate

resilience and the ability to maintain a seal without

extended compression.

4.2 Leak Detection Efficiency

IoT Sensors: Field tests showed that IoT sensors realized

a 92% accuracy rate in detecting oil leaks in operational

transformers. This high accuracy enables maintenance

and reduces the risk of major oil spills.

DGA: While DGA analysis also showed an acceptable

accuracy of 85% in showing potential leak-causing faults,

the results were often delayed by 24 hours due to the

need for laboratory processing.

4.3 Economic and Environmental Impact

Cost Savings: Implementing smart gaskets with integrated sensors is projected to reduce maintenance costs by 18% due to early leak detection and initiative-taking repairs.

Environmental Benefits: By minimizing oil leaks, the adoption of advanced gasket technologies and leak detection methods can contribute to a 15% reduction in oil spills, mitigating environmental damage and promoting sustainability.

4.4 Hypothesis Validation

Hypothesis 1: The hypothesis that the use of advanced gasket materials, such as those made of Viton, would lead

to a reduction in oil leak incidents was supported by the experimental data.

Field tests demonstrated a 12% reduction in oil leaks compared to transformers equipped with conventional gasket materials.

This can be attributed to the superior properties of Viton, such as its higher resistance to heat, chemicals, and aging compared to conventional NBR gaskets. Viton's enhanced resilience and durability contribute to a more robust seal.

Hypothesis 2: The hypothesis that a hybrid leak detection approach combining IoT sensors and DGA would improve

accuracy was also validated, with a 27% increase in accuracy compared to using either method alone.

: Discussion of Results and Recommendations

5.1 Implications for Saudi Arabia

Vision 2030 Alignment: The findings of this research align with Saudi Arabia's Vision 2030 goals, which emphasize environmental protection, economic diversification, and increased operational efficiency in key sectors, including energy.

Operational Efficiency: By reducing transformer downtime and maintenance costs, the proposed solutions contribute to enhancing the operational efficiency of Saudi Arabia's power transmission infrastructure.

5.2 Predictive Maintenance

IoT Integration: The integration of IoT sensors and real-time monitoring capabilities enables predictive maintenance strategies, allowing for initiative-taking repairs and preventing costly transformer failures

5.3 Challenges

High Costs: The initial investment costs associated with advanced gasket materials, such as nanocomposites, can be significantly higher (up to 3 times) compared to conventional NBR gaskets.

Training Gaps: Implementing and effectively utilizing IoT-based monitoring systems require specialized training for

technicians, which may pose a challenge in terms of workforce development.

5.4 Policy Recommendations

procedures: To promote transformer sustainability in Saudi Arabia, procedures could be implemented to mandate the use of UV–stabilized gaskets in transformers located in desert regions, where high temperatures and solar radiation accelerate material degradation.

Motivations: Government motivations and grants could be provided to encourage the adoption of smart gasket technologies and advanced leak detection methods, facilitating the transition towards more sustainable transformer management practices.

Chapter Six: Conclusion and Recommendations

6.1 Summary of Key Findings

NBR gaskets generally perform well under moderate operating conditions; however, Viton gaskets exhibit enhanced performance in high-temperature environments or hotspots within transformers.

IoT sensors significantly improve leak detection accuracy, enabling initiative-taking maintenance and reducing the risk of environmental damage.

6.2 Contributions

This research contributes to the advancement of gasket technology and leak detection methods for power transformers, with a specific focus on the challenges and opportunities in Saudi Arabia.

It provides a framework for sustainable transformer management, aligning with the Kingdom's Vision 2030 goals and promoting environmental protection and economic efficiency.

References

1. Ibrahim, Nivin Farag (2022), *The Green Economy and the Role of Renewable Energy in Providing Electricity in Egypt*, The Scientific Journal of Commercial Research, Issue 2, University of Menoufia.
2. Abu Jamous, Nabhan Salem (2020), *Sustainable Development and its Legal Nature under International Environmental Law*, Journal of Jurisprudence and Law, Salah Al-Din and Kadak.
3. Suleiman, Ahmed Hassan (2019), *Sustainable Development: Knowledge, Skills, and Experiences*, Al-Arabi Journal for Studies and Research, Issue 2, The Arab Center for Research and Media Studies.
4. Mahmoud, Ayoub Mahmoud Hanafi (2019), *The Role of New and Renewable Energy Investments in Achieving Sustainable Development*, The Scientific Journal of Economics and Commerce, Issue 4, pp. 57–78. Retrieved from <http://search.mandumah.com/Record/1067004>
5. Badrouni, Houda (2020), *Investment in Renewable Energies and its Role in Achieving Environmental Protection and Sustainable Development in Algeria*, Journal of Leadership in

- Business Economics, Vol. 6, Issue 3, pp. 128–143. Retrieved from <http://search.mandumah.com/Record/1035433>
6. Ben Naama, Salima (2023), *The Renewable Energy Industry and its Role in Embodying Sustainable Development in Algeria 2011–2021*, Journal of Finance and Markets, Vol. 10, Issue 1, pp. 80–98. Retrieved from <http://search.mandumah.com/Record/1368896>
 7. Belajine, Khalidia (2020), *Leading Global Experiences in Exploiting Renewable Energy – China as a Model*, Journal of Commercial Studies and Contemporary Experiences, Vol. 3, Issue 1, Algeria.
 8. Haiziya, Zaed (2019), *Renewable Energies as a Way to Achieve Sustainable Development in Algeria*, Journal of Commercial Sciences, Vol. 18, Issue 1, Algeria.
 9. Djalil, Mounia (2018), *Investment in Renewable Energies and Achieving Sustainable Development: Reality and Aspirations*, Journal of Legal and Political Thought, Issue 4, pp. 32–52. Retrieved from <http://search.mandumah.com/Record/1071336>
 10. Zamal, Saleh (2020), *The Contract of the Electricity Company Produced from Renewable Energy Sources in Legislation in Algeria*, Al–Mufakker Journal, Vol. 15, Issue 2, University of Mohamed Kheider Biskra.
 11. Shennawi, Nawal (2020), *Sustainable Development and its Measurement Tools*, Al–Manhal Al–Iqtisadi Journal,

University of Echahid Cheikh Larbi Tebessi – El Oued, Vol. 3,
Issue 1.

12. V.K Lakhiani, A.S Jhala T & R India Ltd.

ECOFRIENDLY LEAK PROOF TRANSFORMERS.

13. Md Tasbirul Islam, Amjad Ali Osama E.

Sustainable green energy transition in Saudi Arabia:

Characterizing policy framework, interrelations, and

future research directions.

14. Gouda, Saber M. Saleh, Salah Hamdy EL–Hoshy

Power Transformer Incipient Faults Diagnosis Based on

Dissolved Gas Analysis.

الملخص

تهدف هذه الدراسة إلى معالجة مشكلة تسرب زيت المحولات في البنية التحتية لنقل الطاقة بالمملكة العربية السعودية، مع التركيز على فشل الحشوات كسبب رئيسي. من خلال تحليل آليات تدهور الحشوات، وتقييم طرق الكشف عن التسرب، واستكشاف مواد متقدمة الحشوات مثل المواد النانوية الحشوات الذكية، تسعى هذه الدراسة إلى تعزيز استدامة المحولات. تتوافق الحلول المقترحة مع أهداف رؤية المملكة 2030، التي تؤكد على الحماية البيئية والكفاءة التشغيلية والجدوى الاقتصادية. تم تحليل البيانات التجريبية من الاختبارات المعملية والميدانية، بما في ذلك نتائج قوة الشد والاستطالة والشيخوخة المتسارعة، للتحقق من فعالية تقنيات الحشوات الحديثة. تهدف النتائج إلى تقليل حوادث تسرب الزيت بنسبة 10-15٪، وخفض تكاليف الصيانة، وإطالة عمر المحولات.

Appendices

Questionnaire Form: Transformer Gasket Degradation and Leak Detection in Saudi Arabia

This questionnaire is designed to gather information for a research study on enhancing transformer sustainability in Saudi Arabia by mitigating oil leaks. Your participation is valuable and will contribute to improving the reliability and environmental performance of power transmission infrastructure.

Section 1: General Information

Name (Optional): _____

Job Title: _____

Company/Organization:

Years of Experience in Transformer Maintenance:

Section 2: Gasket Degradation

What types of gasket materials are commonly used in transformers in your experience? (Check all that apply)

Nitrile Butadiene Rubber (NBR)

Viton (FKM)

Silicone

Cork–Nitrile Composites

Other: Please specify

Have you observed gasket degradation in transformers
operating in Saudi Arabia?

Yes

No

If yes, what are the most common types of gasket
degradation you have observed? (Check all that apply)

Cracking

Hardening

Loss of flexibility

Swelling

Shrinking

Other: Please specify

What factors do you believe contribute most significantly to gasket degradation in Saudi Arabia's climate? (Rank in order of importance, with one being the most significant)

High ambient temperatures

Exposure to sunlight (UV radiation)

Sandstorms and dust

Chemical exposure (transformer oil, contaminants)

Mechanical stress and vibration

Other: Please specify

In your opinion, what is the typical lifespan of a
transformer gasket in Saudi Arabia?

Section 3: Leak Detection

What leak detection methods are currently used in your
company/organization? (Check all that apply)

Visual inspection

Dissolved Gas Analysis (DGA)

IoT sensors

Acoustic detection

Pressure measurement

Other: Please specify

How effective are these methods in detecting leaks early and preventing major oil spills? (Please provide a rating for each method used, with 1 being very ineffective and 5 being highly effective)

Visual inspection: 1 2 3 4 5

Dissolved Gas Analysis (DGA): 1 2 3 4 5

IoT sensors: 1 2 3 4 5

Acoustic detection: 1 2 3 4 5

Pressure measurement: 1 2 3 4 5.

Other: Please specify method and

rating_____

What are the main challenges or limitations of the current

leak detection

methods?_____

What improvements or advancements in leak detection

technology would you like to

see?_____

Section 4: Advanced Gasket Technologies

Are you familiar with advanced gasket materials, such as

nanocomposites or smart gaskets?

Yes

No

If yes, what are your thoughts on their potential to

improve transformer sustainability in Saudi

Arabia? _____

What are the potential benefits of using advanced gasket

materials? (Check all that apply)

Increased lifespan

Improved sealing performance

Reduced leak frequency

Enhanced resistance to degradation

Lower maintenance costs

Other: Please specify

What are the potential challenges or concerns associated with adopting advanced gasket materials? (Check all that apply)

High initial cost

Compatibility with existing transformers

Lack of awareness or knowledge

Availability in the Saudi market

Other: Please specify

Section 5: Sustainable Maintenance Practices

What are the current maintenance practices for transformers in your company/organization?

How often are transformers inspected for leaks?

What are the typical procedures for repairing oil leaks?

What measures are taken to prevent environmental damage in case of an oil spill?

What suggestions do you have for improving transformer maintenance practices to enhance sustainability?

Section 6: Policy Recommendations

What policy recommendations would you suggest
promoting the adoption of advanced gasket technologies
and sustainable transformer management practices in
Saudi Arabia? _____

Thank you for your participation!



جامعة ميدأوشن

كلية الإدارة

تخصص إدارة المشاريع

تعزيز استدامة المحولات في مشاريع نقل الطاقة بالمملكة العربية السعودية: دراسة سياقية
لتقنيات الحشوات المتطورة وطرق الكشف عن التسرب للحد من تسرب الزيت

أسم الطالب/ عيسى حسن الغزواني

الرقم الجامعي / 242001036

إشراف/

د. الفیصل عبدالحمید

د. فايز جراد

2025