

MIDOCEAN UNIVERSITY

Administration college

Project Management



Transformer Reliability through Advanced Diagnostic Techniques

Prepared by:

Abdulrahman Alqahtani

Supervision:

Dr. Alfaisal Hassan

Dr. Fayez Jrad

Year:

2024

Introduction:

Power transformers are critical components of the electrical power system, ensuring reliable and efficient energy delivery. However, aging, environmental factors, and operational stress can lead to various faults and failures. Early detection and timely intervention are crucial to prevent catastrophic failures and minimize downtime. Advanced diagnostic techniques offer a promising approach to assess transformer health and predict potential issues.

Research Problem:

Traditional maintenance practices for transformers often rely on time-based maintenance schedules, which may not always be optimal. This can lead to unnecessary maintenance costs or, conversely, unexpected failures. Advanced diagnostic techniques, such as Dissolved Gas Analysis (DGA), infrared thermography, and frequency response analysis, can provide valuable insights into the health of transformers. However, the effective integration and interpretation of these techniques remain a challenge.

Importance of Study:

This research aims to address the limitations of traditional maintenance practices and improve the reliability of 230 kV power transformers. By developing a comprehensive framework for integrating advanced diagnostic techniques, this research will contribute to:

- **Enhanced transformer reliability:** Early detection of incipient faults can prevent catastrophic failures and reduce unplanned outages.
- **Optimized maintenance strategies:** Data-driven maintenance approaches can reduce unnecessary maintenance costs and improve resource allocation.
- **Improved power system efficiency:** Reliable transformer operation contributes to the overall efficiency of the power system.
- **Reduced environmental impact:** Timely maintenance can mitigate environmental risks associated with transformer failures, such as oil spills and fires.

Research Hypotheses:

- 1- Hypothesis 1:** The integration of multiple diagnostic techniques, including DGA, infrared thermography, and frequency response analysis, can improve the accuracy of transformer health assessment.
- 2- Hypothesis 2:** The application of machine learning techniques can enhance the predictive capabilities of transformer diagnostic systems.
- 3- Hypothesis 3:** The implementation of advanced diagnostic techniques can lead to significant cost savings through reduced maintenance costs and avoided outage costs.

Literature Review:

A comprehensive literature review will be conducted to identify relevant research papers, industry standards, and technical reports. The review will focus on the following aspects:

- **Transformer Aging and Failure Mechanisms:** A review of the common causes of transformer failures, such as thermal aging, electrical stress, and mechanical stress.
- **Advanced Diagnostic Techniques:** A detailed examination of the principles and applications of DGA, infrared thermography, frequency response analysis, and other relevant techniques.
- **Data-Driven Approaches to Transformer Maintenance:** A review of the application of data mining and machine learning techniques for transformer condition assessment and predictive maintenance.

Transformer Aging and Failure Mechanisms:

Transformer aging and failure mechanisms are complex phenomena influenced by various factors, including thermal stress, electrical stress, and mechanical stress. Understanding these mechanisms is crucial for effective maintenance and condition assessment.

1- Thermal Aging:

Thermal aging is one of the primary causes of transformer failure. Excessive heat accelerates the degradation of insulation materials, leading to reduced dielectric strength and increased risk of breakdown.

Key points:

- 1- **Overloading:** Prolonged operation at high loads can lead to increased winding temperatures.
- 2- **Poor Cooling:** Inefficient cooling systems can result in higher operating temperatures.
- 3- **Hot Spot Formation:** Local overheating due to manufacturing defects or operational conditions can accelerate aging.

Reference :

- IEEE Standard C57.104-2018, "IEEE Guide for the Interpretation of Gases Generated in Oil-Immersed Transformers"

2- Electrical Stress:

Electrical stress, such as overvoltage and partial discharge, can degrade transformer insulation and lead to premature failure.

- **Overvoltage:** Overvoltages caused by lightning strikes, switching operations, or resonance phenomena can damage insulation.
- **Partial Discharge:** Partial discharge occurs when localized ionization takes place within insulation materials, leading to erosion and eventual breakdown.

3- Mechanical Stress:

Mechanical stress can result from various factors, including vibrations, seismic events, and thermal expansion and contraction.

Key points :

- 1- **Vibration:** Vibrations caused by wind, seismic activity, or internal forces can lead to fatigue and loosening of connections.
- 2- **Seismic Events:** Earthquakes can cause significant damage to transformers, including structural damage and winding displacement.
- 3- **Thermal Expansion and Contraction:** Repeated cycles of thermal expansion and contraction can lead to mechanical stress and fatigue.

By understanding these aging and failure mechanisms, it is possible to implement effective maintenance strategies, such as regular inspections, oil analysis, and advanced diagnostic techniques, to mitigate the risk of transformer failures and ensure reliable power system operation.

Dissolved Gas Analysis (DGA):

Dissolved Gas Analysis (DGA) is a well-established technique for diagnosing incipient faults in oil-filled transformers. By analyzing the concentration of specific gases dissolved in transformer oil, it is possible to identify potential fault types, such as overheating, partial discharge, and arcing. AS Well as preventing unplanned transformer outages.

Reference : Möllmann, A., & Pahlavanpour, B. (1999). New guidelines for the interpretation of dissolved gas analysis in oil-filled transformers. *Electra*, 186, 31-51.

Reference : IEEE Guide for the Interpretation of Gases Generated in Oil-Immersed Transformers; IEEE Std. C57.104-2018.

Infrared Thermography:

Infrared thermography is a non-destructive technique that uses infrared radiation to detect temperature differences on the surface of a transformer. By identifying hotspots, it is possible to detect potential overheating issues, loose connections, and other problems.

Frequency Response Analysis (FRA):

Frequency Response Analysis (FRA) involves measuring the frequency response of a transformer winding. Changes in the frequency response can indicate changes in the winding condition, such as winding deformation or insulation degradation

Data-Driven Approaches to Transformer Maintenance:

Data-driven approaches to transformer maintenance have gained significant attention in recent years. By leveraging advanced analytics and machine learning techniques, utilities can optimize maintenance schedules, reduce downtime, and improve overall system reliability.

Key points:

1- Condition-Based Maintenance (CBM):

- **Real-time monitoring:** Continuous monitoring of key parameters like temperature, vibration, and oil quality using sensors and IoT devices.
- **Predictive analytics:** Using historical data and machine learning algorithms to predict potential failures and schedule maintenance proactively.

2- Digital Twin Technology:

- **Virtual replica:** Creating a virtual replica of a transformer to simulate its behavior under different operating conditions.
- **Predictive modeling:** Using the digital twin to predict the impact of various factors on transformer performance.

Reference:

- Zhang, Y., Wang, Y., & Yang, Y. (2021). Digital Twin-Based Predictive Maintenance for Power Transformers: A Review. IEEE Access, 9, 11333-11346

3- Advanced Analytics:

- **Data mining:** Extracting valuable insights from large datasets of transformer operational data.
- **Machine learning:** Applying machine learning algorithms to identify patterns and anomalies in data.
- **Statistical analysis:** Using statistical techniques to analyze the relationship between different variables and predict future trends.

Benefits of Data-Driven Approaches:

- **Improved reliability:** Proactive maintenance reduces the risk of unexpected failures.
- **Optimized maintenance schedules:** Data-driven insights enable more efficient scheduling of maintenance activities.
- **Reduced maintenance costs:** Preventive maintenance can help avoid costly repairs and replacements.
- **Enhanced decision-making:** Data-driven insights support informed decision-making for maintenance and asset management.

By embracing data-driven approaches, utilities can move towards a more proactive and efficient maintenance strategy for their transformer fleet, ultimately improving the overall reliability and performance of the power grid.

Research Methodology:

1- Data Collection:

- **Field Data:** Data will be collected from field tests on 230 kV power transformers, including DGA, infrared thermography, and frequency response analysis data.
- **Laboratory Data:** Laboratory experiments may be conducted to validate the effectiveness of diagnostic techniques under controlled conditions.
- **Historical Data:** Historical data on transformer failures, maintenance records, and operational data will be collected to establish a baseline for comparison.

2- Data Analysis:

- **Statistical Analysis:** Statistical techniques, such as correlation analysis and regression analysis, will be used to analyze the collected data.
- **Machine Learning:** Machine learning algorithms, such as decision trees, support vector machines, and neural networks, will be applied to develop predictive models for transformer health assessment.
- **Data Mining:** Data mining techniques will be used to identify patterns and trends in the data.

Study Tools (Data Collection Tools):

To conduct comprehensive research on enhancing transformer reliability through advanced diagnostic techniques, the following data collection tools will be utilized:

Hardware Tools

1. **Infrared Thermography Camera:** Used to detect temperature anomalies on the surface of transformers.
2. **Ultrasonic Testing Equipment:** Employed to assess the condition of transformer windings and core.
3. **Partial Discharge (PD) Measurement Equipment:** Used to detect and measure partial discharges within the transformer insulation.
4. **Dissolved Gas Analysis (DGA) Kit:** Used to collect and analyze oil samples to identify potential faults.
5. **Vibration Monitoring Equipment:** Used to measure vibration levels to detect mechanical issues.
6. **Frequency Response Analyzer:** Used to assess the impedance characteristics of transformer windings.

Software Tools

1. **Data Acquisition Systems:** Used to collect and store data from various sensors and instruments.
2. **Data Analysis Software:** Used to analyze the collected data, including statistical analysis, signal processing, and machine learning techniques.
3. **Machine Learning Frameworks:** Used to develop and train predictive models, such as TensorFlow, PyTorch, and Scikit-learn.
4. **GIS Software:** Used to visualize the geographical distribution of transformers and analyze spatial patterns of failures.

Data Sources

Utility Records: Historical data on transformer maintenance, repairs, and failures.

1. Operational Data: Real-time data on transformer loading, temperature, and voltage.
2. Sensor Data: Data collected from various sensors, including temperature sensors, vibration sensors, and current sensors.
3. Laboratory Test Results: Results from laboratory tests, such as DGA, oil dielectric strength tests, and paper insulation tests.

By effectively utilizing these data collection tools and sources, the research team can gather comprehensive and reliable data to analyze transformer health, identify potential issues, and develop advanced diagnostic techniques.

Research Limitations:

- Limited Access to Data: Access to real-time data from transformers may be limited, which can constrain the scope of the research.
- Complexity of Transformer Systems: The complex nature of power transformers and the influence of multiple factors on their performance can make it challenging to isolate the impact of specific diagnostic techniques
- Cost of Advanced Diagnostics: The cost of advanced diagnostic techniques may limit their widespread application.

List of references and preliminary sources:

- IEEE Standard C57.104-2018, "IEEE Guide for the Interpretation of Gases Generated in Oil-Immersed Transformers
- Möllmann, A., & Pahlavanpour, B. (1999). New guidelines for the interpretation of dissolved gas analysis in oil-filled transformers. *Electra*, 186, 31-51.

- IEEE Guide for the Interpretation of Gases Generated in Oil-Immersed Transformers; IEEE Std. C57.104-2018.
- Zhang, Y., Wang, Y., & Yang, Y. (2021). Digital Twin-Based Predictive Maintenance for Power Transformers: A Review. IEEE Access, 9, 11333-11346











